



LATERAL SPECIFICATIONS:

1. 4" DIAMETER IS THE MINIMUM SIZE. LARGER SIZES WILL BE SPECIFIED BY THE AUTHORITY WHEN THE AMOUNT OF FLOW WARRANTS.
2. SLOPE SHALL BE A MINIMUM OF 1/4" PER FOOT.
3. CLEANOUTS MUST BE INSTALLED EVERY 50' ON 4" PIPE, AND EVERY 100' ON 6" PIPE TO INCLUDE DEPTH.
4. LATERALS SHALL BE LAID IN AGGREGATE CUSHION AND BEDDING.
5. CLEANOUT TERMINAL(S) SHALL HAVE TREATMENT AT RESPECTIVR LOCATION. REFER TO DWG. #15.

INSPECTION:

1. WORK MUST BE INSPECTED AND TESTED BEFORE BACKFILLING.
2. INSPECTIONS WILL BE BILLED AT THE RATE IN EFFECT AT THE TIME OF INSPECTION.

**TYPICAL MULTI-FAMILY UNIT
LATERAL INSTALLATION**

NOT TO SCALE

TYPICAL MULTI-FAMILY UNIT
LATERAL INSTALLATION

**SPRING - BENNER - WALKER
JOINT AUTHORITY**

DATE	4/05
SCALE	NTS
PROJECT	
SHEET	12