



NOTES:

1. MINIMUM INSIDE HEADROOM IN VALVE PIT IS 6'-0".
2. MINIMUM WET WELL DIAMETER IS 6'-0".
MINIMUM VALVE PIT DIAMETER IS 5'-0".
3. PUMPS AND FLOATS MUST BE CAPABLE OF REMOVAL WITHOUT ENTERING WET WELL BY USE OF SLIDERAIL ASSEMBLY.
4. A 30" X 48" ACCESS DOOR MAY BE USED WHERE VALVE PIT DIAMETER IS 5'-0".
5. ALL ELECTRICAL CONNECTIONS MUST BE OUTSIDE OF WETWELL.

WET WELL LIFT STATION AND VALVE PIT GENERAL SCHEMATIC- SECTION VIEW

NOT TO SCALE

WET WELL LIFT STATION
AND VALVE PIT
GENERAL SCHEMATIC
SECTION VIEW

**SPRING - BENNER - WALKER
JOINT AUTHORITY**

DATE
4/05
SCALE
NTS
PROJECT
SHEET
20